

RESOLUTION NO. 91-144
=====

A RESOLUTION OF THE LODI CITY COUNCIL
AWARDING THE BID FOR THE PURCHASE OF 15-KV CONCENTRIC
NEUTRAL CABLE FOR ELECTRIC UTILITY DEPARTMENT
=====

WHEREAS, in answer to notice duly published in accordance with law and the order of this City Council, sealed bids were received and publicly opened on July 23, 1991 at 11:00 a.m. for the bid for 30,000 feet of #2 Aluminum, 15-kv, concentric neutral, jacketed cable, described in the specifications therefor approved by the City Council on June 20, 1991; and

WHEREAS, said bids have been compared, checked, and tabulated and a report thereof filed with the City Manager as shown on Exhibit A, attached hereto; and

WHEREAS, the City Manager recommends that award of the bid for 15-kv concentric neutral cable be made to the low bidder, Delta Pacific Sales, of Yuba City;

NOW, THEREFORE, BE IT RESOLVED by the Lodi City Council that award of bid for 30,000 feet of #2 Aluminum, 15-kv, concentric neutral, jacketed cable be and the same is hereby awarded to Delta Pacific Sales, the low bidder, in the amount of \$27,508.58.


Dated: August 7, 1991
=====

I hereby certify that Resolution No. 91-144 was passed and adopted by the City Council of the City of Lodi in a regular meeting held August 7, 1991 by the following vote:

Ayes: Council Members - Pennino, Pinkerton, Sieglock,
Snider and Hinchman (Mayor)

Noes: Council Members - None

Absent: Council Members - None


Alice M. Reimche
City Clerk

B I D R E S U L T S

#2 Aluminum 15-kv Concentric Neutral Jacketed Cable
Bids Opened July 23, 1991

Delta Pacific Sales, Yuba City	\$27,508.58
	27,153.00 *
Reynolds Metals, Richmond, VA	27,605.55
Westinghouse Electric, Concord	28,316.70 *
Power & Communications, Orinda	28,316.70 * (1)
Maydwell & Hartzell, Brisbane	29,189.48 *
Pirelli Wire & Cable, Colusa	29,351.10
Capital Wholesale Electric, Sacramento	29,965.28 *
Okonite Company, San Ramon	33,230.10 * (2)

NOTES:

- * Prices subject to escalation, based on daily quotes of copper and aluminum;
- (1) Proposed cable does not meet specifications for insulation materials;
- (2) Proposed cable does not meet specifications for insulation materials, or for curing process.